



www.ruralmembershipwater.com

Mailing: PO BOX 239 / Physical: 301 S. Ferguson St
 Henryville, IN47126
 Office: 812-294-1481 / Fax: 812-294-1743
 PWSID # 5210009

2017 Consumer Confidence Report Amendment

5210009 Rural Membership Water Corp Test Results

Lead and Copper	Collection Date	MCLG	Action Level	90 th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2017	1.3	1.3	0.579	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing system
Lead	2017	0	15	1	0	ppb	N	Erosion of natural deposits; Corrosion of household plumbing system

5210010 Sellersburg Water Test Results

Lead and Copper	Collection Date	MCLG	Action Level	90 th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2017	1.3	1.3	0.568	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing system
Lead	2017	0	15	1.5	0	ppb	N	Erosion of natural deposits; Corrosion of household plumbing system

5272002 Stucker Fork Water Test Results

Lead and Copper	Collection Date	MCLG	Action Level	90 th Percentile	# of Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2017	1.3	1.3	0.081	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing system
Lead	2017	0	15	1	0	ppb	N	Erosion of natural deposits; Corrosion of household plumbing system

Lead and Copper

Definitions: Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.